



S. B. STEELS COMPANY



GOVT. REGISTERED (190162108303) & BIS APPROVED /
ISO (9001) APPROVED METALLURGICAL TESTING LABORATORY

LABORATORY : 366/6 & 366/1, G. T. ROAD, BALLY, HOWRAH - 711 201 (W.B.)
H. O. : 36, STRAND ROAD, 4TH FLOOR, ROOM NO. 16, KOLKATA-700001

SBS-F-9

Rev. No.-01 dt. 03.02.2020
Ph. Lab. : 2654-1858
Fax Lab. : (033) 2654-2145
Ph. H.O. : 2243-2017/1903
Fax H.O. : (033) 2243-1205

CERTIFICATE No.
TC-5979
NABL ACCREDITED
LABORATORY
ISO/IEC 17025:2017

Test Report

Page 01 of 01

SAMPLE RECD. ON 13.07.2022. dt. 13.07.2022.
ORDER REF. NO Nil. Brand Name – ELEGANT.
ULR NO. TC597922000001204F
SAMPLE DESCRIPTION 02 Nos. 08mm. dia TMT Bar 1 mtr long.
SPECIFICATION IS:1786/2008, Gr. Fe 550D, Amndt. No. 4, July 2019.
ISSUED TO M/s. Bortoria, Madandih, Shakambhari Ispat And Power Ltd., Raghunathpur Road, Madandih, Purulia, W.B.

TESTED ON 13-18.07.2022
L. No. 2714
T.C.NO. SBSCP01204
DATE 18.07.2022.
STAMPED Nil.

* This is to certify that the above Sample(s) has/have been tested with the following results *

CHEMICAL ANALYSIS BY SPECTRO & MECHANICAL TEST

Elements %	Findings	Requirements
C	0.1925	0.25 Max.
S	0.0221	0.040 Max.
P	0.0251	0.040 Max.
Mass (Kg/m)	0.406	0.395±7%
Y.S. (N/mm ²)	582	550 Min.
T.S. (N/mm ²)	636	600 Min.
%Elg. on 5.65√S ₀	18.68	14.50 Min.
Bend Test (180°, 4Ø)	Satisfactory.	Shall pass the test.
Rebend Test (135°, 157.5°, 6Ø)	Satisfactory.	Shall pass the test.


Remarks : The above test results obtained, conform to the specified value.

Tested Sample Returned.

dc

ORIGINAL

- TEST WITNESS BY :
- * ENVIRONMENTAL CONDITION :
 - * ESTIMATED UNCERTAINTY (IF APPLICABLE) :
 - * SAMPLE NOT DRAWN BY US
 - * SPECIFICATION USED FOR TEST IS: 8811-98, R.A. 2018, IS: 1608(Pl.1)/2018,
 - * TEST CERTIFICATE RELATES TO THE SAMPLE ONLY IS: 1599/2019, IS: 1786/2008.
 - * SAMPLE WILL BE CEASED IF NOT TAKEN BACK WITHIN 15 DAYS



For S. B. STEELS COMPANY

SANTANU KR. PAL
Technical Manager
(Authorised Signatory)

TESTING FACILITIES APPROVED BY—LOYDS, PDIL, IRS, TRF, BHEL, NPB, EIA, DEFENCE, ABB (ABL LTD.) CESC, BV, VSP, FCI, DNV, PGCIL, CLW, PWD, CPT, DGS. & D, PIEN, BALCO, RDSO, N.T.P.C, WBSEB, DSP, GEC, RITES, L & T, TATA EXPORT & OTHER INSPECTION AUTHORITIES.

THE STATEMENT OF THE REPORT SHALL NOT BE REPRODUCED IN FULL/PART WITHOUT THE PRIOR WRITTEN CONSENT OF THE ISSUING AUTHORITY.
QUALITY CONTROL & INSPECTION / SERVICE TO THE NATION



S. B. STEELS COMPANY



SBS-F-9

GOVT. REGISTERED (190162108303) & BIS APPROVED /
ISO (9001) APPROVED METALLURGICAL TESTING LABORATORY
LABORATORY : 366/6 & 366/1, G. T. ROAD, BALLY, HOWRAH - 711 201 (W.B.)
H. O. : 36, STRAND ROAD, 4TH FLOOR, ROOM NO. 16, KOLKATA-700001

Rev. No.-01 dt. 03.02.2020
Ph. Lab. : 2654-1858
Fax Lab. : (033) 2654-2145
Ph. H.O. : 2243-2017/1903
Fax H.O. : (033) 2243-1205

CERTIFICATE No.
TC-5979
NABL ACCREDITED
LABORATORY
ISO/IEC 17025:2017

Test Report

Page 01 of 01

L. No. : 7715

TESTED ON 13-18.07.2022
T.C.NO. SBSCP01204/1
DATE 18.07.2022.
STAMPED Nil.

SAMPLE RECD. ON 13.07.2022.
ORDER REF. NO Nil. dt. 13.07.2022.
ULR NO. TC597922000001204F Brand Name - ELEGANT.
SAMPLE DESCRIPTION 02 Nos. 10mm. dia TMT Bar 1 mtr long.
SPECIFICATION IS:1786/2008, Gr. Fe 550D, Amndt. No. 4, July 2019.
ISSUED TO M/s. Bortoria, Madandih, Shakambhari Ispat And Power Ltd., Raghunathpur Road, Madandih, Purulia, W.B.

* This is to certify that the above Sample(s) has/have been tested with the following results *

CHEMICAL ANALYSIS BY SPECTRO & MECHANICAL TEST

Elements %	Findings	Requirements
C	0.1654	0.25 Max.
S	0.0152	0.040 Max.
P	0.0196	0.040 Max.
Mass (Kg/m)	0.613	0.617±7%
Y.S. (N/mm ²)	591	550 Min.
T.S. (N/mm ²)	649	600 Min.
%Elg. on 5.65√S ₀	17.84	14.50 Min.
Bend Test (180°, 4Ø)	Satisfactory.	Shall pass the test.
Rebend Test (135°, 157.5°, 6Ø)	Satisfactory.	Shall pass the test.

Remarks : The above test results obtained, conform to the specified value.

Tested Sample Returned.

dc

ORIGINAL

- TEST WITNESS BY :
- * ENVIRONMENTAL CONDITION :
 - * ESTIMATED UNCERTAINTY (IF APPLICABLE) :
 - * SAMPLE NOT DRAWN BY US
 - * SPECIFICATION USED FOR TEST IS: 8811-98, R.A. 2018, IS: 1608(Pt.1)/2018,
 - * TEST CERTIFICATE RELATES TO THE SAMPLE ONLY IS: 1599/2019, IS: 1786/2008.
 - * SAMPLE WILL BE CEASED IF NOT TAKEN BACK WITHIN 15 DAYS



For S. B. STEELS COMPANY

SANDEEP KR. PAI
Technical Manager
(Authorised Signatory)

TESTING FACILITIES APPROVED BY—LOYDS, PDIL, IRS, TRF, BHEL, NPB, EIA, DEFENCE, ABB (ABL LTD.) CESC, BV, VSP, FCI, DNV, PGCIL, CLW, PWD, CPT, DGS. & D, PIEN, BALCO, RDSO, N.T.P.C, WBSEB, DSP, GEC, RITES, L & T, TATA EXPORT & OTHER INSPECTION AUTHORITIES.

THE STATEMENT OF THE REPORT SHALL NOT BE REPRODUCED IN FULL/PART WITHOUT THE PRIOR WRITTEN CONSENT OF THE ISSUING AUTHORITY.
QUALITY CONTROL & INSPECTION / SERVICE TO THE NATION



S. B. STEELS COMPANY



GOVT. REGISTERED (190162108303) & BIS APPROVED /
ISO (9001) APPROVED METALLURGICAL TESTING LABORATORY

LABORATORY : 366/6 & 366/1, G. T. ROAD, BALLY, HOWRAH - 711 201 (W.B.)
H. O. : 36, STRAND ROAD, 4TH FLOOR, ROOM NO. 16, KOLKATA-700001

SBS-F-9

Rev. No.-01 dt. 03.02.2020
Ph. Lab. : 2654-1858
Fax Lab. : (033) 2654-2145
Ph. H.O. : 2243-2017/1903
Fax H.O. : (033) 2243-1205
L. No. : **7716**

CERTIFICATE No.
TC-5979
NABL ACCREDITED
LABORATORY
ISO/IEC 17025:2017

Test Report

Page 01 of 01

TESTED ON 13-18.07.2022.
T.C.NO. SBSCP01204/2
DATE 18.07.2022.
STAMPED Nil.

SAMPLE RECD. ON 13.07.2022.
ORDER REF. NO Nil. dt. 13.07.2022. Brand Name - ELEGANT.
ULR NO. TC597922000001204F
SAMPLE DESCRIPTION 02 Nos. 12mm. dia TMT Bar 1 mtr long.
SPECIFICATION IS:1786/2008, Gr. Fe 550D, Amndt. No. 4, July 2019.
ISSUED TO M/s. Bortoria, Madandih, Shakambhari Ispat And Power Ltd., Raghunathpur Road, Madandih, Purulia, W.B.

* This is to certify that the above Sample(s) has/have been tested with the following results *

CHEMICAL ANALYSIS BY SPECTRO & MECHANICAL TEST

Elements %	Findings	Requirements
C	0.1854	0.25 Max.
S	0.0155	0.040 Max.
P	0.0128	0.040 Max.
Mass (Kg/m)	0.894	0.888±5%
Y.S. (N/mm ²)	585	550 Min.
T.S. (N/mm ²)	648	600 Min.
%Elg. on 5.65√S ₀	18.07	14.50 Min.
Bend Test (180°, 4Ø)	Satisfactory.	Shall pass the test.
Rebend Test (135°, 157.5°, 7Ø)	Satisfactory.	Shall pass the test.

Remarks : The above test results obtained, conform to the specified value.

Tested Sample Returned.

dc

ORIGINAL

- TEST WITNESS BY :
- * ENVIRONMENTAL CONDITION :
 - * ESTIMATED UNCERTAINTY (IF APPLICABLE) :
 - * SAMPLE NOT DRAWN BY US IS: 8811-98, IS: 1608(Pt.1)/2018, IS: 1599/2019, IS: 1786/2008
 - * SPECIFICATION USED FOR TEST
 - * TEST CERTIFICATE RELATES TO THE SAMPLE ONLY
 - * SAMPLE WILL BE CEASED IF NOT TAKEN BACK WITHIN 15 DAYS



For S. B. STEELS COMPANY

SANTOSH KR. PAI
Technical Manager

(Authorised Signatory)

TESTING FACILITIES APPROVED BY—LOYDS, PDIL, IRS, TRF, BHEL, NPB, EIA, DEFENCE, ABB (ABL LTD.) CESC, BV, VSP, FCI, DNV, PGCIL, CLW, PWD, CPT, DGS. & D, PIEN, BALCO, RDSO, N.T.P.C, WBSEB, DSP, GEC, RITES, L & T, TATA EXPORT & OTHER INSPECTION AUTHORITIES.

THE STATEMENT OF THE REPORT SHALL NOT BE REPRODUCED IN FULL/PART WITHOUT THE PRIOR WRITTEN CONSENT OF THE ISSUING AUTHORITY.
QUALITY CONTROL & INSPECTION / SERVICE TO THE NATION



S. B. STEELS COMPANY



GOVT. REGISTERED (190162108303) & BIS APPROVED /
ISO (9001) APPROVED METALLURGICAL TESTING LABORATORY

LABORATORY : 366/6 & 366/1, G. T. ROAD, BALLY, HOWRAH - 711 201 (W.B.)
H. O. : 36, STRAND ROAD, 4TH FLOOR, ROOM NO. 16, KOLKATA-700001

SBS-F-9

Rev. No.-01 dt. 03.02.2020
Ph. Lab. : 2654-1858
Fax Lab. : (033) 2654-2145
Ph. H.O. : 2243-2017/1903
Fax H.O. : (033) 2243-1205
L. No. : **7717**

CERTIFICATE No.
TC-5979
NABL ACCREDITED
LABORATORY
ISO/IEC 17025:2017

Test Report

Page 01 of 01

SAMPLE RECD. ON 13.07.2022.
ORDER REF. NO Nil. dt. 13.07.2022.
ULR NO. TC597922000001204F Brand Name – ELEGANT.
SAMPLE DESCRIPTION 02 Nos. 16mm. dia TMT Bar 1 mtr long.
SPECIFICATION IS:1786/2008, Gr. Fe 550D, Amndt. No. 4, July 2019.
ISSUED TO M/s. Bortoria, Madandih, Shakambhari Ispat And Power Ltd., Raghunathpur Road, Madandih, Purulia, W.B.

TESTED ON 13-18.07.2022.
T.C.NO. SBSCP01204/3
DATE 18.07.2022.
STAMPED Nil.

* This is to certify that the above Sample(s) has/have been tested with the following results *

CHEMICAL ANALYSIS BY SPECTRO & MECHANICAL TEST

Elements %	Findings	Requirements
C	0.1754	0.25 Max.
S	0.0165	0.040 Max.
P	0.0154	0.040 Max.
Mass (Kg/m)	1.617	1.58±7%
Y.S. (N/mm ²)	575	550 Min.
T.S. (N/mm ²)	629	600 Min.
%Elg. on 5.65√S ₀	19.01	14.50 Min.
Bend Test (180°, 4Ø)	Satisfactory.	Shall pass the test.
Rebend Test (135°, 157.5°, 7Ø)	Satisfactory.	Shall pass the test.

Remarks : The above test results obtained, conform to the specified value.

Tested Sample Returned.

dc

ORIGINAL

- TEST WITNESS BY :
- * ENVIRONMENTAL CONDITION :
 - * ESTIMATED UNCERTAINTY (IF APPLICABLE) :
 - * SAMPLE NOT DRAWN BY US
 - * SPECIFICATION USED FOR TEST IS: 8811-98, RA. 2018, IS: 1608(Pt.1)/2018, IS: 1599/2019, IS: 1786/2008.
 - * TEST CERTIFICATE RELATES TO THE SAMPLE ONLY
 - * SAMPLE WILL BE CEASED IF NOT TAKEN BACK WITHIN 15 DAYS



For S. B. STEELS COMPANY

SANJAY K. PAL
Technical Manager
(Authorised Signatory)

TESTING FACILITIES APPROVED BY—LOYDS, PDIL, IRS, TRF, BHEL, NPB, EIA, DEFENCE, ABB (ABL LTD.) CESC, BV, VSP, FCI, DNV, PGCIL, CLW, PWD, CPT, DGS. & D, PIEN, BALCO, RDSO, N.T.P.C, WBSEB, DSP, GEC, RITES, L & T, TATA EXPORT & OTHER INSPECTION AUTHORITIES.

THE STATEMENT OF THE REPORT SHALL NOT BE REPRODUCED IN FULL/PART WITHOUT THE PRIOR WRITTEN CONSENT OF THE ISSUING AUTHORITY.
QUALITY CONTROL & INSPECTION / SERVICE TO THE NATION



S. B. STEELS COMPANY



GOVT. REGISTERED (190162108303) & BIS APPROVED /
ISO (9001) APPROVED METALLURGICAL TESTING LABORATORY

LABORATORY : 366/6 & 366/1, G. T. ROAD, BALLY, HOWRAH - 711 201 (W.B.)
H. O. : 36, STRAND ROAD, 4TH FLOOR, ROOM NO. 16, KOLKATA-700001

SBS-F-9

Rev. No.-01 dt. 03.02.2020
Ph. Lab. : 2654-1858
Fax Lab. : (033) 2654-2145
Ph. H.O. : 2243-2017/1903
Fax H.O. : (033) 2243-1205
L. No. : **7718**

CERTIFICATE No.
TC-5979
NABL ACCREDITED
LABORATORY
ISO/IEC 17025:2017

Test Report

Page 01 of 01

SAMPLE RECD. ON 13.07.2022.

ORDER REF. NO Nil. dt. 13.07.2022.

ULR NO. TC597922000001204F Brand Name - ELEGANT.

SAMPLE DESCRIPTION 02 Nos. 20mm. dia TMT Bar 1 mtr long.

SPECIFICATION IS:1786/2008, Gr. Fe 550D, Amndt. No. 4, July 2019.

ISSUED TO M/s. Bortoria, Madandih, Shakambhari Ispat And Power Ltd., Raghunathpur Road, Madandih, Purulia, W.B.

TESTED ON 13-18.07.2022.
T.C.NO. SBSCP01204/4
DATE 18.07.2022.
STAMPED Nil.

* This is to certify that the above Sample(s) has/have been tested with the following results *

CHEMICAL ANALYSIS BY SPECTRO & MECHANICAL TEST

Elements %	Findings	Requirements
C	0.1854	0.25 Max.
S	0.0189	0.040 Max.
P	0.0168	0.040 Max.
Mass (Kg/m)	2.478	2.47±3%
Y.S. (N/mm ²)	602	550 Min.
T.S. (N/mm ²)	653	600 Min.
%Elg. on 5.65√S ₀	17.66	14.50 Min.
Bend Test (180°, 4Ø)	Satisfactory.	Shall pass the test.
Rebend Test (135°, 157.5°, 7Ø)	Satisfactory.	Shall pass the test.

Remarks : The above test results obtained, conform to the specified value.

Tested Sample Returned.

dc

ORIGINAL

- TEST WITNESS BY :
- ★ ENVIRONMENTAL CONDITION :
 - ★ ESTIMATED UNCERTAINTY (IF APPLICABLE) :
 - ★ SAMPLE NOT DRAWN BY US
 - ★ SPECIFICATION USED FOR TEST IS: 8811-98, IS: 1599/2019, IS: 1786/2008.
 - ★ TEST CERTIFICATE RELATES TO THE SAMPLE ONLY
 - ★ SAMPLE WILL BE CEASED IF NOT TAKEN BACK WITHIN 15 DAYS



For S. B. STEELS COMPANY

SANTOSH R. PAL
Technical Manager
(Authorised Signatory)

TESTING FACILITIES APPROVED BY—LOYDS, PDIL, IRS, TRF, BHEL, NPB, EIA, DEFENCE, ABB (ABL LTD.) CESC, BV, VSP, FCI, DNV, PGCIL, CLW, PWD, CPT, DGS. & D, PIEN, BALCO, RDSO, N.T.P.C, WBSEB, DSP, GEC, RITES, L & T, TATA EXPORT & OTHER INSPECTION AUTHORITIES.

THE STATEMENT OF THE REPORT SHALL NOT BE REPRODUCED IN FULL/PART WITHOUT THE PRIOR WRITTEN CONSENT OF THE ISSUING AUTHORITY.
QUALITY CONTROL & INSPECTION / SERVICE TO THE NATION



S. B. STEELS COMPANY



GOVT. REGISTERED (190162108303) & BIS APPROVED /
ISO (9001) APPROVED METALLURGICAL TESTING LABORATORY

LABORATORY : 366/6 & 366/1, G. T. ROAD, BALLY, HOWRAH - 711 201 (W.B.)
H. O. : 36, STRAND ROAD, 4TH FLOOR, ROOM NO. 16, KOLKATA-700001

SBS-F-9

Rev. No.-01 dt. 03.02.2020
Ph. Lab. : 2654-1858
Fax Lab. : (033) 2654-2145
Ph. H.O. : 2243-2017/1903
Fax H.O. : (033) 2243-1205
L. No. : **7719**

CERTIFICATE No.
TC-5979
NABL ACCREDITED
LABORATORY
ISO/IEC 17025:2017

Test Report

Page 01 of 01

SAMPLE RECD. ON 13.07.2022.

ORDER REF. NO Nil. dt. 13.07.2022.

ULR NO. TC597922000001204F Brand Name - ELEGANT.

SAMPLE DESCRIPTION 02 Nos. 25mm. dia TMT Bar 1 mtr long.

SPECIFICATION IS:1786/2008, Gr. Fe 550D, Amndt. No. 4, July 2019.

ISSUED TO M/s. Bortoria, Madandih, Shakambhari Ispat And Power Ltd., Raghunathpur Road, Madandih, Purulia, W.B.

TESTED ON 13-18.07.2022.

T.C.NO. SBSCP01204/5

DATE 18.07.2022.

STAMPED Nil.

* This is to certify that the above Sample(s) has/have been tested with the following results *

CHEMICAL ANALYSIS BY SPECTRO & MECHANICAL TEST

Elements %	Findings	Requirements
C	0.1911	0.25 Max.
S	0.0128	0.040 Max.
P	0.0119	0.040 Max.
Mass (Kg/m)	3.827	3.85±3%
Y.S. (N/mm ²)	603	550 Min.
T.S. (N/mm ²)	661	600 Min.
%Elg. on 5.65√S ₀	19.36	14.50 Min.
Bend Test (180°, 5Ø)	Satisfactory.	Shall pass the test.
Rebend Test (135°, 157.5°, 7Ø)	Satisfactory.	Shall pass the test.

Remarks : The above test results obtained, conform to the specified value.

Tested Sample Returned.

dc

ORIGINAL

TEST WITNESS BY :

- ★ ENVIRONMENTAL CONDITION :
- ★ ESTIMATED UNCERTAINTY (IF APPLICABLE) :
- ★ SAMPLE NOT DRAWN BY US
- ★ SPECIFICATION USED FOR TEST IS: 8811-98, R.A. 2018, IS: 1608(Pl.1)/2018.
- ★ TEST CERTIFICATE RELATES TO THE SAMPLE ONLY: IS: 1599/2019, IS: 1786/2008.
- ★ SAMPLE WILL BE CEASED IF NOT TAKEN BACK WITHIN 15 DAYS



For S. B. STEELS COMPANY

SANTOSH K. PAL
Technical Manager
(Authorised Signatory)

TESTING FACILITIES APPROVED BY—LOYDS, PDIL, IRS, TRF, BHEL, NPB, EIA, DEFENCE, ABB (ABL LTD.) CESC, BV, VSP, FCI, DNV, PGCIL, CLW, PWD, CPT, DGS. & D, PIEN, BALCO, RDSO, N.T.P.C, WBSEB, DSP, GEC, RITES, L & T, TATA EXPORT & OTHER INSPECTION AUTHORITIES.

THE STATEMENT OF THE REPORT SHALL NOT BE REPRODUCED IN FULL/PART WITHOUT THE PRIOR WRITTEN CONSENT OF THE ISSUING AUTHORITY.
QUALITY CONTROL & INSPECTION / SERVICE TO THE NATION



S. B. STEELS COMPANY



SBS-F-9

GOVT. REGISTERED (190162108303) & BIS APPROVED /
ISO (9001) APPROVED METALLURGICAL TESTING LABORATORY
LABORATORY : 366/6 & 366/1, G. T. ROAD, BALLY, HOWRAH - 711 201 (W.B.)
H. O. : 36, STRAND ROAD, 4TH FLOOR, ROOM NO. 16, KOLKATA-700001

Rev. No.-01 dt. 03.02.2020
Ph. Lab. : 2654-1858
Fax Lab. : (033) 2654-2145
Ph. H.O. : 2243-2017/1903
Fax H.O. : (033) 2243-1805
L. No. : **7720**

CERTIFICATE No.
TC-5979
NABL ACCREDITED
LABORATORY
ISO/IEC 17025:2017

Text Report

Page 01 of 01

SAMPLE RECD. ON 13.07.2022. TESTED ON 13-18.07.2022.
ORDER REF. NO Nil. dt. 13.07.2022. T.C.NO. SBSCP01204/6
ULR NO. TC597922000001204F Brand Name - ELEGANT. DATE 18.07.2022.
SAMPLE DESCRIPTION 02 Nos. 32mm. dia TMT Bar 1 mtr long. STAMPED Nil.
SPECIFICATION IS:1786/2008, Gr. Fe 550D, Amndt. No. 4, July 2019.
ISSUED TO M/s. Bortoria, Madandih, Shakambhari Ispat And Power Ltd., Raghunathpur Road, Madandih, Purulia. W.B.

* This is to certify that the above Sample(s) has/have been tested with the following results *

CHEMICAL ANALYSIS BY SPECTRO & MECHANICAL TEST

Elements %	Findings	Requirements
C	0.1752	0.25 Max.
S	0.0129	0.040 Max.
P	0.0121	0.040 Max.
Mass (Kg/m)	6.293	6.31±3%
Y.S. (N/mm ²)	585	550 Min.
T.S. (N/mm ²)	640	600 Min.
%Elg. on 5.65√S ₀	18.50	14.50 Min.
Bend Test (180°, 5Ø)	Satisfactory.	Shall pass the test.
Rebend Test (135°, 157.5°, 7Ø)	Satisfactory.	Shall pass the test.


Remarks : The above test results obtained, conform to the specified value.

Tested Sample Returned.

dc

ORIGINAL

- TEST WITNESS BY :
- ★ ENVIRONMENTAL CONDITION :
 - ★ ESTIMATED UNCERTAINTY (IF APPLICABLE) :
 - ★ SAMPLE NOT DRAWN BY US
 - ★ SPECIFICATION USED FOR TEST IS: 8811-98, R.A. 2019 (REVISED) (Pt. 1)/2018.
 - ★ TEST CERTIFICATE RELATES TO THE SAMPLE ONLY 599/2019, IS: 1786/2008.
 - ★ SAMPLE WILL BE CEASED IF NOT TAKEN BACK WITHIN 15 DAYS



For S. B. STEELS COMPANY

SANJOY KR. PA
Technical Manager
(Authorised Signatory)

TESTING FACILITIES APPROVED BY—LOYDS, PDIL, IRS, TRF, BHEL, NPB, EIA, DEFENCE, ABB (ABL LTD.) CESC, BV, VSP, FCI, DNV, PGCIL, CLW, PWD, CPT, DGS. & D, PIEN, BALCO, RDSO, N.T.P.C, WBSEB, DSP, GEC, RITES, L & T, TATA EXPORT & OTHER INSPECTION AUTHORITIES.

THE STATEMENT OF THE REPORT SHALL NOT BE REPRODUCED IN FULL/PART WITHOUT THE PRIOR WRITTEN CONSENT OF THE ISSUING AUTHORITY.
QUALITY CONTROL & INSPECTION / SERVICE TO THE NATION